

SCHOOL ACCESS AUDIT PLAN - SANDIWAY PRIMARY SCHOOL

Question	Yes/No	Details
Checklist 1 – Approach routes & Street furniture		
1.1 - Is the school within convenient walking distance of – <ul style="list-style-type: none"> - Public Highway and Pathways? - Public Transport e.g. bus stops - Carparking? 	Yes	The school is located on a main road, bus stops are a 10-minute walk away and a train station is a 10-minute walk away. The school has a staff car park and use of three local car parks all located between a 1 minute and 5-minute walk away.
1.2 – Route free of kerbs? Do crossings on approach have tactile paving? If there is a pedestrian crossing, do these have turn cones to aid people who are Deafblind?	No	The roads all have curbed pathways. There is a pelican crossing located outside near the school which has tactile paving, there are no turn cones.
1.3 – Wide enough? If a route or pathway is narrow, is there a suitable passing place for wheelchair users? Is plantation trimmed and are low branches avoided?	Yes	
1.4 – Surfaces even and slip resistant? Is paving flush with no cracks or gaps that could trap the wheels of a wheelchair?	No	The main pathways are in reasonable state of repair, some areas may be difficult for wheelchair users.
1.5 – Is the location of the school clearly identified from the street? Visual clues and sufficient landmarks to aid orientation?	Yes	The school has big signs which indicate the school and directions to access the school.
1.6 – Free from hazards such as bollards, litter bins? Are planting features kept to a minimum and are they colour contrasted?	Yes	All litter bins are placed off the main pavement and planting kept away from the pathways.
1.7 – Free from hazardous building features such as outward opening doors, windows or overhangs? Do columns or structural posts have markings at two heights?	Yes	The school is set in its own grounds and doesn't impact the main approach routes
1.8 - Adequate seating provided along routes? Is there seating where parents wait to pick up / drop off their children?	Yes	Lots on benches and seating areas within the school grounds
Checklist 2 – Car Parking		
2.1 - Are accessible bays provided for badge holders?	Yes	2 bays in staff car park and 2 bays in the local car park
2.2 - Accessible bays clearly sign-posted from the school's car park entrance? Is there signage to the front of the bays?	Yes/No	Staff car park has road markings only
2.3 - Are bays marked out appropriately and easily identified? Can car doors be fully opened to allow disabled drivers and passengers to transfer to a wheel chair parked alongside?	Yes	
2.4 - Close enough to facilities the car park serves?	Yes	

SCHOOL ACCESS AUDIT PLAN - SANDIWAY PRIMARY SCHOOL

2.5 - Routes from parking area to school entrance accessible, with dropped kerbs and appropriate tactile warnings? Car park surface smooth, even and free from loose stones?	Yes	
2.6 - For larger car parks, are safety marked out walking routes provided to guard slow moving persons or people with hearing impairments?	N/A	
Checklist 3 - External Ramps		
3.1 - Wide enough and suitably graded? Is there colour contrast to the surface of the ramp?	N/A	
3.2 - Suitable handrails on each side?	N/A	
3.3 - Surface slip-resistant, firmly fixed and easy to maintain?	N/A	
3.4 - Edges protected to prevent accidents?	N/A	
Checklist 4 - External Steps		
4.1 - Visual and tactile warnings at the top and bottom of steps?	No	
4.2 - Suitable handrails on each side? Are handrails suitably colour contrasted to aid people with impaired vision?	No	
4.3 - Lighting adequate and well positioned? Are steps appropriately illuminated during darker hours?	Yes	
4.4 - Treads long enough and all the same length?	Yes	Single Steps
4.5 - Risers shallow enough, all the same height, and unlikely to trip users? Are there open risers?	N/A	
4.6 - Nosing's readily identifiable? If nosing's are painted, is the paint still durable with no wear and tear?	No	
Checklist 5 – Entrances		
5.1 - Main school entrances easy to find? Is the entrance clearly distinguishable from facade?	Yes	
5.2 - Door opening wide enough for all users? Enough space alongside leading edge for a wheel chair user to open the door while clear of the door swing?	Yes	
5.3 - Level or flush threshold?	Yes	Level
5.4 - If there are steps at the main entrance, is there signage indicating where the accessible entrance is located?	N/A	
5.5 - Can people each side of the door, either standing or seated, see each other and be seen? If the entrance is solid, is this due to security concerns?	Yes	

SCHOOL ACCESS AUDIT PLAN - SANDIWAY PRIMARY SCHOOL

5.6 - Door control at a suitable height for both standing and seated users? Are door handles clearly located, easy to use and grip?	Yes	
5.7 - Door closer of appropriate type? Can the door be easily opened single handily?	Yes	
5.8 - Entry phones and intercoms detailed to allow use by people with sensory or mobility impairments? Is there an LED display to accommodate people with hearing impairments?	N/A	None fitted
5.9 - Glazed entrance door: markings for safety and visibility? If manifestations are provided, are these suitably colour contrasted against their background	No	
5.10 - Weather mat of firm texture and flush with floor?	Yes	Flat Mat
Checklist 6 - Reception Areas and Lobbies		
6.1 - Clear view in from outside? Can receptionists see visitors and provide assistance if necessary?	Yes	CCTV monitors the entrance way
6.2 - Transitional lighting? Is the entrance lobby and reception area well illuminated?	Yes	
6.3 - Reception/desk/counter/ checkout suitable for approach and use from both sides by people either standing and seated?	No	Staff will assist those who cannot access the office window
6.4 - Surfaces suitable? Is there colour contrast to the flooring in front of the reception desk and are edges highlighted?	Yes	
6.5 - Induction loop fitted? Is there signage indicating the availability of the facility? Are front line staff aware of the facility and its purpose?	No	No induction loop
Checklist 7 - Corridors and Internal Surfaces		
7.1 - Corridor wide enough for a wheel chair user to manoeuvre and for other people to pass? Turning space for wheel chair users?	Yes	
7.2 - Free from obstruction to wheel chair users and from hazards to people with impaired sight? Are there any internal columns that have a lack of colour contrast?	Yes	
7.3 - Are all key facilities within the school accessible for all users? E.g. Sport Hall, Main Hall, Music Room, Changing Room etc. Where there are facilities not available can these be 'swopped' with a standard classroom?	Yes	
7.4 - Floor surfaces suitable for passage of wheelchairs? Junctions between floor surfaces correctly detailed?	Yes	

SCHOOL ACCESS AUDIT PLAN - SANDIWAY PRIMARY SCHOOL

7.5 - Colours, tones and textures varied to help people distinguish between surfaces and fixtures and fittings? Do the floors suitably colour contrast against the walls (this can also be achieved by having well contrasted skirting boards)	Yes	
7.6 - Floor surfaces slip-resistant? Bright, boldly patterned floors avoided? Busy or distracting wall coverings avoided?	Yes	
Checklist 8 - Internal Doors		
8.1 - Distinguishable from surroundings?	Yes/No	Three older doors are a similar colour to the walls
8.2 - Glass door: clearly visible when closed? Are manifestations suitably colour contrasted against the background?	N/A	
8.3 - Can people each side of the door, either standing or seated, see each other and be seen? Are vision panels kept clear of temporary notices? (for an example classroom entrances)	Yes	
8.4 - Clear opening width sufficient for a wheel chair user? Adequate space available alongside leading edge for a wheel chair user to open the door while clear of the door swing	Yes	
8.5 - Door control at a height suitable for both standing and seated users? Easily gripped and operated? Control clearly distinguishable from the door itself?	Yes	
8.6 - Door light enough to open easily? Door closers of an appropriate type and with minimum necessary opening pressure?	Yes	Some doors are heavy
Checklist 9 - Internal Ramps		
9.1 - Ramp available for short rise within single storey?	N/A	
9.2 - Wide enough and suitably graded? Surface slip resistant?	N/A	
9.3 - Exposed edges protected to prevent accidents?	N/A	
9.4 - Suitable handrail each side?	N/A	
Checklist 10 - Internal Stairs		
10.1 - Treads long enough and each of same length?	N/A	
10.2 - Risers shallow enough, all the same height, and unlikely to trip users?	N/A	
10.3 - Nosing's readily identifiable?	N/A	
10.4 - Suitable handrails on each side? Do handrails extend 300mm beyond the first and last step pitch-line? Are handrails suitably colour contrasted?	N/A	

SCHOOL ACCESS AUDIT PLAN - SANDIWAY PRIMARY SCHOOL

10.5 - Landings big enough and provided at intermediate levels in a long flight?	N/A	
Checklist 11 – Lifts		
11.1 - Passenger lift available for vertical circulation within a building of more than one storey?	N/A	
11.2 - Car dimensions sufficient to allow space for wheel chair user? Door opens wide enough for wheel chair users?	N/A	
11.3 - Support rails in car appropriately designed and positioned	N/A	
11.4 - Is there a mirror within the lift car?	N/A	
11.5 - Delayed-action closer and override (not a door pressure system) to allow slow entry or exit?	N/A	
11.6 - Controls, including emergency call, located easily using visual or tactile information and within easy reach of all users?	N/A	
11.7 - Voice indication of floor reached? Is audio loud enough to be heard by hearing aid users?	N/A	
11.8 - Is there a floor level indicator inside and outside the lift to reassure people with hearing impairments?	N/A	
Checklist 12 - WC Provision & Changing Areas		
12.1 - Lobby door light enough to open easily? Lobby of sufficient size for easy access?	Yes	
12.2 - Slip-resistant floors throughout?	Yes	
12.3 - Fittings all easily distinguishable from background? Are hand dryers and sanitary ware easily seen against their surroundings	Yes	
12.4 - Compartment door controls all easily gripped and operated? Are cubicle doors suitably colour contrasted against the panels?	Yes	
12.5 - Are urinals well contrasted and do they have grab rails to assist people with ambulant disabilities?	N/A	
12.6 - Are lever style taps provided within the WCs to aid people with dexterity impairments?	Yes	
7 - When there is no accessible WC available, is there a facility provided for people with ambulant disabilities?	N/A	
12.8 - Where there are shower facilities, is a grab rail provided? Is there a level access shower for disabled people?	N/A	
Checklist 13 - WCs: Wheelchair Users		

SCHOOL ACCESS AUDIT PLAN - SANDIWAY PRIMARY SCHOOL

13.1 - Compartment large enough to allow manoeuvring into position for frontal, lateral, angled and backward transfer unassisted and with assistance?	Yes	
13.2 - Travel distance to a suitable WC no greater than that for able-bodied people?	Yes	
13.3 - Sufficient space available outside toilet compartment for manoeuvre? Is the entrance wide enough and does it open outwards?	Yes	
13.4 - Hand washing and dry facilities within easy reach of someone seated on WC? Is the hand basin suitably positioned in accordance to BS8300?	Yes	
13.5 - Door controls, lock and light switch easily reached and operated? Is there a grab rail to the inner face of the entrance?	Yes	
13.6 - Tap appropriate for use by a person with limited dexterity, grip of strength?	Yes	
13.7 - Suitably designed grab rails fitted in all positions necessary to assist manoeuvring? Are grab rails suitably colour contrasted to aid people with impaired vision?	Yes	
13.8 - Is there a back rest provided to the toilet pan?	No	None fitted
13.9 - Is the flush of a suitable spatula type and is it appropriately located on the transfer side of the toilet pan	Yes/No	Correct handle fitted but on the none transfer side
13.10 - Is the transfer side of the toilet pan kept clear of any obstacles that may deny wheelchair users all the transferring techniques in which an accessible WC is designed to provide?	Yes	
13.11 - Is there a cord alarm? Is this coloured red with two triangular bangles and easy to reach from floor level?	Yes	
Checklist 14 – Facilities		
14.1 - Are seats provided at intervals along long internal routes or where waiting likely? Seats stable, with armrests and provided in a range of heights? Space for wheelchair user to pull up alongside a seated companion?	No	Seats have no armrests
14.2 - Are chairs with armrests provided within the Staff Room and other key locations such as meeting areas?	Yes	
14.3 - Are a number of chairs with armrests available within each classroom?	Yes	Staff have armrests on their seats

SCHOOL ACCESS AUDIT PLAN - SANDIWAY PRIMARY SCHOOL

14.4 - Do dining room counters have provision on both sides for wheelchair users? Do these counters have an induction loop to accommodate hearing aid users?	Yes/ No	No induction loop
14.5 - Do vending machines have all operating parts at less than 1200mm off the floor level and are they suitably colour contrasted?	N/A	
14.6 - Does the dining room have appropriate seating rather than fixed seating which can be inaccessible for a range of users?	No	Mobile tables with fixed seats are placed out each lunchtime, aces to the side of the tables is possible
14.7 - Is there a dropped counter and an induction loop available for the Library counter?	N/A	
14.8 - Where there are IT facilities i.e. within classrooms and the Library (if applicable) are height adjustable computer desks available?	No	
14.9 - In the Main Hall, is the stage raised? If so what is the current procedure for wheelchair users? For an example when receiving awards on Speech Day?	No	Stage is a temporary one, Wheelchair users stay on ground level
Checklist 15 - Way Finding		
15.1 - Overall layout of school reasonably clear and logical? Is there signage available in Braille and tactile?	Yes/No	Toilets
15.2 - On entering the reception area, are signs designed and located to convey information to visitors with sight impairments and wheel chair users with lower eye levels?	No	
15.3 - Are standard toilet facilities suitably signed? On approach and on the actual entrances? Are the locations of the accessible WC facilities suitably identified and located? Does signage have the International Symbol of Access? (Wheelchair symbol)	Yes	
15.4 - Within stairwells are each of the levels clearly identifiable by tactile and visual information?	N/A	
15.5 - Are the location of the lifts clearly signed at key locations throughout the school? Is there lift signage near the reception area and on entry to key stairwells?	N/A	
Checklist 16 - Lighting & Acoustics		
16.1 - Lighting designed to meet a wide range of user's needs? Level of lighting sufficient for intended use? Lights positioned where they do not cause glare, reflection, confusing shadows or pools of light and dark?	Yes	

SCHOOL ACCESS AUDIT PLAN - SANDIWAY PRIMARY SCHOOL

16.2 - Can occupiers control lighting? Are light switch plates suitably colour contrasted and appropriately positioned for a wheelchair user?	Yes/No	Some areas in the older build the switches are not at wheelchair height
16.3 - Are classrooms appropriately illuminated and are blinds available to control the natural day lighting? Is glare avoided which can hinder attempts by people with hearing impairments to lipread?	Yes	
16.4 - Quiet and noisy areas separated by a buffer zone? Environment free from unnecessary obtrusive noise (e.g. heating units)	No	Blow air system through most of school
16.5 - Good balance of hard and soft surfaces?	Yes	
16.6 - Are induction loops fitted within the key areas i.e.- Main Hall, Sports Hall, key study areas e.g. Music Room.	No	
Checklist 17 - Means of Escape		
17.1 - Audible alarm system supplemented by visual system?	Yes/No	New build area and assembly hall have visual and audible alarm, the rest of the school is audible only
17.2 - Ground floor exit routes accessible to all, including wheel chair users, as entrance routes?	No	All fire exits in the older part of the school the classrooms require going down a step, the new build and main entrance have flush exits.
17.3 - Once outside, can a wheelchair user get to a place of safety? Are pathways provided and are these wide enough?	Yes	
17.4 - Vertical escape from upper to lower floors possible using a fire-protected lift with an independent power supply?	N/A	
17.5 - If disabled people are unable to leave the building, is there a suitable refuge area? Is there an intercom provided within the refuge area and does this have accessible features such as an LED display?	No	
Checklist 18 - Building Management		
18.1 - External Routes; Including steps and ramps, kept clean, unobstructed and free from surface water, snow and ice?	Yes	No external ramps
18.2 - Accessible parking; Designated spaces not used by nondisabled drivers and kept free from obstructions?	Yes	
18.3 - Horizontal circulation; Space required for wheel chair manoeuvre not obstructed by furniture, deliveries, storage etc.?	Yes	
18.4 - Vertical circulation; Lifts, platform lifts and stair lifts checked regularly for proper functioning?	N/A	

SCHOOL ACCESS AUDIT PLAN - SANDIWAY PRIMARY SCHOOL

18.5 - Means of Escape; Exit routes checked regularly for freedom from obstacles (including locked doors) and combustible materials? Alarm systems, including those in WCs, regularly checked?	Yes	As per fire evacuation and lockdown policy
Checklist Checked by Deborah Bertram Headteacher	Date 01/11/ 2024	